SIEMENS

Data sheet 6EP4133-0JB00-0AY0

SITOP UPS1100/BAT. MODULE/24V/5AH/LIFEPO

********** spare part ********* SITOP UPS1100 battery module with maintenance-free sealed lithium iron phosphate batteries for SITOP DC UPS modules 24 V DC 5 Ah

electrical data	
end-of-charge voltage at DC	
● at -10 °C recommended	28.8 V
● at 0 °C recommended	28.8 V
● at 10 °C recommended	28.8 V
● at 20 °C recommended	28.8 V
● at 30 °C recommended	28.8 V
● at 40 °C recommended	28.8 V
● at 50 °C recommended	28.8 V
output	
battery capacity	5 A·h
output current rated value	20 A
output current in buffering mode maximum	20 A
peak current	60 A; for 30 ms
charging current maximum	2.1 A
output voltage at DC rated value	24 V
interfaces	
communication function	Yes
protection and monitoring	
design of short-circuit protection	Battery fuse 25 A/32 V (FKS blade-type fuse + holder); overcurrent switch-off at 60 A > 30 ms/min and 24 A > 5 s/min
design of the overload protection	Valve control
display version for normal operation	LED green: Battery OK; LED flashing green: Error or warning; OFF: No communication
safety	
operating resource protection class	Class III
protection class IP	IP20
standards, specifications, approvals	
certificate of suitability	
● CE marking	Yes
● UL approval	Yes; cURus-Recognized (UL 1778, CSA C22.2 No. 107.1), File E219627
● CSA approval	No
● EAC approval	Yes
standards, specifications, approvals hazardous environments	
certificate of suitability	
● ATEX	No
● cCSAus, Class 1, Division 2	No
standards, specifications, approvals marine classification	
shipbuilding approval	Yes
Marine classification association	
● American Bureau of Shipping Europe Ltd. (ABS)	Yes
● Det Norske Veritas (DNV)	Yes
ambient conditions	
ambient condition	For storage, mounting and operation of batteries, the relevant DIN/VDE regulations or country-specific regulations (e.g. VDE 0510 Part 2/EN 50272-2) must be observed.
ambient temperature	
● during operation	-20 ... +50
● during transport	-40 ... +60
● during storage	-20 ... +35

Subject to change without notice
© Copyright Siemens
Downloaded from Arrow.com.

relative temporary capacity loss at 20 °C in a month typical	3 %
service life	
service life of energy storage	
● typical	capacity falls to 80 % of original capacity (according to EUROBAT)
● at 20 °C typical	15 a
● at 30 °C typical	10 a
● at 40 °C typical	9 a
● at 50 °C typical	2 a
note	Along with the storage and operating temperature, other factors such as the duration of the storage period and the charge status during storage have a decisive influence on the possible useful life. Batteries should therefore be stored as briefly as possible, always fully charged, and within the temperature range 0 to +20 °C.
connection method	
type of electrical connection	screw terminal
● for UPS module	1 screw terminal each for 0.5 ... 16 mm² for + BAT and - BAT
● for control circuit and status message	1 screw terminal each for 0.14 ... 4 mm²
mechanical data	
width × height × depth of the enclosure	189 × 186 × 113 mm
installation width × mounting height	189 mm × 201 mm
required spacing	
● top	15 mm
● bottom	0 mm
● left	0 mm
● right	0 mm
fastening method	snaps onto DIN rail EN 60715 35x15 or keyhole mounting for hooking in to M4 screws
● DIN-rail mounting	Yes
● S7 rail mounting	No
● wall mounting	Yes
net weight	3.4 kg
number of cells	16
accessories	
product component included	Accessories pack with solid-state circuitry fuse 25 A
further information internet links	
internet link	
● to website: Industry Online Support	https://support.industry.siemens.com
additional information	
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)
security information	
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications

	Version	Classification
eClass	14	27-05-04-03
eClass	12	27-05-04-03
eClass	9.1	27-05-04-03
eClass	9	27-05-04-03

Subject to change without notice
© Copyright Siemens
Downloaded from Arrow.com.

eClass	8	27-05-04-03
eClass	7.1	27-05-04-03
eClass	6	27-05-04-90
ETIM	9	EC000357
ETIM	8	EC000357
ETIM	7	EC000357
UNSPSC	15	32-15-17-06

Approvals Certificates

General Product Approval		Marine / Shipping	
Manufacturer Declaration	Declaration of Conformity		

last modified: 11/8/2024

Subject to change without notice
© Copyright Siemens
Downloaded from Arrow.com.