CERTIFICATE OF COMPLIANCE

Certificate Number	20130320 – E69455
Report Reference	E69455 - 20060131
Issue Date	2013-March-20
Issued to:	SIEMENS INDUSTRY INC 5400 TRIANGLE PKY NW NORCROSS, GA 30092 USA
This is to certify that representative samples of	Circuit-breaker Accessories Circuit breaker accessories - Undervoltage release, Types UVRL. (See following page for additional model information.) Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures." CAN/CSA-C22.2 No. 5-2002, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.
The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with “C” and “US” identifiers: c UL us the word “LISTED”; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

CERTIFICATE OF COMPLIANCE

Certificate Number 20130320 – E69455
Report Reference E69455 - 20060131
Issue Date 2013-March-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Model Information:

General Character and Use:

These devices are intended for use in Siemens CG, DG, FG, JG and LG frame circuit breakers described in E10848, Volume 14.

These devices are intended for factory or field installation.

Catalog Numbers and Ratings:

Catalog Number	Voltage	Max Current (mA)	Frequency
UVRLA12DC	12 V DC	65	DC
UVRLB24DC	24 V DC	32	DC
UVRLC48DC	48 V DC	16	DC
UVRLG60DC	60 V DC	13	DC
UVRLD125DC	110-127 V DC	6.3	DC
UVRLE250DC	220-250 V DC	3.5	DC
UVRLL24	24 V AC	60	50/60 Hz
UVRLN120	110-127 V AC	16	50/60 Hz
UVRLP208	208 V AC	9	50/60 Hz
UVRLR240	220-250 V AC	8	50/60 Hz
UVRLS277	277 V AC	7.5	50/60 Hz
UVRLT415	380-415 V AC	5	50/60 Hz
UVRLU480	440-480 V AC	4.5	50/60 Hz
UVRLW525	500-525 V AC	4.5	50/60 Hz

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus