CERTIFICATE OF COMPLIANCE

Certificate Number	20130320 – E69455
Report Reference	E69455 - 20050102
Issue Date	2013-March-20
Issued to:	SIEMENS INDUSTRY INC 5400 TRIANGLE PKY NW NORCROSS, GA 30092 USA
This is to certify that representative samples of	Circuit-breaker Accessories Circuit Breaker Accessories, Neutral Sensing Transformers, Cat. Nos. NGSD060, NGSF100, NGSF150, NGSJ250, NGSL400, NGSM600, NGSN800, NGSP120, NGSP160. (See following page for additional model information.) Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: (UL) with the word “LISTED”; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

CERTIFICATE OF COMPLIANCE

Certificate Number	20130320 – E69455
Report Reference	E69455 - 20050102
Issue Date	2013-March-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Model Information:

General Character:

These devices are intended for use with ground fault trip elements applied on a system with the neutral conductor. They are for use with this manufacturer's Listed, DG, FG, JG, LG, MG, NG & PG Frame molded-case circuit breakers with electronic trip units covered in File E10848, Vol. 12, Sec. 1-3.

Ratings:

Cat. No.	Ampere Rating	Frame Size
NGSD060	60 A	DG Frame
NGSF100	100 A	DG & FG Frame
NGSF150	150 A	DG & FG Frame
NGSJ250	250 A	FG & JG Frame
NGSL400	400 A	JG & LG Frame
NGSM600	600 A	MG & LG Frame
NGSN800	800 A	MG & NG Frame
NGSP120	1200 A	NG & PG Frame
NGSP160	1600 A	PG Frame

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus